Instructions: Exchange Laser Optic Module and update parameters

Datum: 25.7.2016

1.) Components of the Laser Optic Module

Located in a central position inside the inner casing shell, the laser optic module (014008-001-25) is suspended on and fixed with four screws to two guide rails. In its lower part, the laser optic module is additionally attached to a steel angle bracket. This prevents undue strain impacts onto the laser optic module, mainly during transportation. Once the four screws have been removed and all cable connections been removed from the laser optic module, it can be taken off.

The laser optic module is designed as a die-cast aluminum part that provides a physical link between all involved light-handling components.

This setup ensures that:

- the various components will accurately preserve their mutual positions
- "laser optic module" components are interchangeable with each other.

Figure 6 and Figure 7 show the setup of essential laser optic module components and cross-sectional views of the emitter and the receiver channel.





Fig. 6: Laser optic module components

- 1 Switch, wired [25]
- 2 Cartridge heater
- 3 Heat sink
- 4 Laser head [59]
- 5 Laser head alignment unit
- 6 Laser optic module cable [15] with thermo sensor
- 7 Emitter channel
- 8 Trigger board [6]
- 9 Receiver channel
- 10 APD alignment unit
- 11 APD unit [29]

Instructions: Exchange Laser Optic Module and update parameters

Datum: 25.7.2016

2.) Recommended tools



Instructions: Exchange Laser Optic Module and update parameters

Datum: 25.7.2016

3.) Remove the Laser Optic Module




Fig. 20: Cable connection points

- 1 Laser optic module cable connector 4 Laser cable connector
- 2 Cable 4 connector 5 Connector lug of cable 20
- 3 Cable 19 connector 6 Cable 5 connector

Attention: Power off the ceilometer!

Please remove all the shown cables.

Attention: At <u>last</u> remove cable point 5, the connector lug of cable 20 between Laser heatsink and Laser controller case (locked flat connector 6.35mm).

#1) After that unfast the 4 screws (2 on each bottom side, lose protected). The screws in the back are problematic.

Speicherdat.: 25.07.2016 09:40	Page 3 / 4
Exchange the Laser Optic Module	

Instructions: Exchange Laser Optic Module and update parameters

Datum: 25.7.2016

- #2) Remove the shield fixing screw of cable 19.
- #3) Remove the looking screws for the D-Sub hood of cable 19.
- #4) Remove the fixing screw on the bottom of the Laser Optic Module.

Take out the Laser Optic Module, be careful about cable 19. Park the Laser optic Module on a table, do not prop up on heatsink of the Laser.

5.) Mounting the Laser Optic Module

Bring in the Laser Optic Module, be careful with cable 19. Mount the 4 screws (#1, 2 on each bottom side). The screws in the back are problematic.

Mount the fixing screw (#4) on the bottom of the Laser Optic Module.

Attention: At <u>first</u> connect cable point 5, the connector lug of cable 20 between Laser heatsink and Laser controller case (locked flat connector 6.35mm).

Fix the shield of cable 19 (#2).

Fix the looking screws for the D-Sub hood of cable 19 (#3).

Connect all the other shown cables.

Power on the CHM15k.

Speicherdat.: 25.07.2016 09:40 Exchange the Laser Optic Module	Page 4 / 4
Exchange the Laser Optic Module	